


CERTIFICATE

Certificate holder	ATAG Verwarming Nederland B.V. Galileïstraat 27 7131 PE LICHTENVOORDE NETHERLANDS
Production facility	De Lier
Product	Solar collectors
Type, Model	SolarCollector II 1,6m ²
Testing basis	DIN EN 12975-1:2011-01 DIN EN 12975-2:2006-06 DIN EN ISO 9806:2014-03 Specific CEN KEYMARK Scheme Rules for Solar Thermal Products version 21.00 (2013-10)
Mark of conformity	
Registration No.	011-7S2441 F
Valid until	2019-12-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

ANNEX

Page 1 of 1

Certificate 011-7S2441 F dated 2014-12-03

Technical Data See data sheet, part of the test report of 2014-11-27

Note(s):

- The freeze resistance test according to DIN EN ISO 9806, clause 15 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.

- The optional impact resistance test was carried out according to DIN EN 12975-2, clause 5.10.

**Testing laboratory/
Inspection body** ISFH - Institut für
Solarenergieforschung GmbH
Hameln/Emmerthal
Am Ohrberg 1
31860 Emmerthal
GERMANY

Test report(s) 76-14/KB datedn 2014-12-02

