



Declaration

Number	66564	Replaces	--
Issued	08-02-2012	Scope	EN 483
Report number	178195		
PIN	0063BT3195		

Kiwa hereby declares that the examined **Central Heating Boilers** of the following types

A160S, A180S, A200S *, A200S(OV) *, A203C/P, A220S, A240S, A260S, A320S *, A163C, A183C, A203C *, A223C, A243C, A253C, A244C, A245C, A244C L, A244EC A244 C L/P, A264C, A285C, A325C *, A243C/P, A285C/P, A285EC, A285EC/P, A325EC *, E160S, E180S, E200S *, E200S(OV) *, E203C/P, A220S, E240S, E260S, E320S *, E163C, E183C, E203C *, E223C, E243C, E253C, E244C, E244C L, E244C L/P, E264C, E285C, E325C *, E243C/P, E285C/P, E285EC, E285EC/P, E244EC, E325EC * .

All product types can be apply with:

- non-return valve installed, indicated (HP)
- build in expansion vessel, indicated (V)
- * only UK type's since 2010, indicated (X)

manufactured by **ATAG Verwarming Nederland B.V.**
Lichtenvoorde, The Netherlands

meet the NO_x-emission requirements specified in the **EN 483:1999 Gas-fired central heating boilers**, type C boilers of nominal heat input not exceeding 70 kW and consequently may carry the following symbol:

NO_x Class: 5

This declaration was drawn up in Apeldoorn, The Netherlands on **08 February 2012** and remains valid until the construction of the products is changed.

