

Number	65003	Replaces	--
Issued	25-10-2011	Scope	EN 483 EN 15420
Report number	179648		
PIN	0063CM3648		

Kiwa hereby declares that the examined **Condensing Central Heating Boilers** of the following types:


**XL 70, XL 105, XL 110, XL 140**

manufactured by **ATAG Verwarming Nederland BV**  
**Lichtenvoorde, The Netherlands**

meet the NO<sub>x</sub>-emission requirements specified in the EN 483:1999 – A2:2001 Gas-fired central heating boilers - type C boilers of nominal heat input not exceeding 70 kW; respectively EN 15420:2010 Gas-fired central heating boilers - type C boilers of nominal heat input exceeding 70 kW but not exceeding 1000 kW, and consequently may carry the following symbol:

**NO<sub>x</sub> Class: 5**

This declaration was drawn up in Apeldoorn, The Netherlands on 25-10-2011 and remains valid until the construction of the products is changed.



Bouke Meekma  
Kiwa

**CE**  
**0063**